

 Open access • Proceedings Article • DOI:10.1109/EEEIC.2015.7165266

Double soft-computing techniques based triple functionalities for Shunt Active Power Filter with voltage source inverter topology — Source link

Nfa Abdul Rahman, Mohd Amran Mohd Radzi, A. Che Soh, Norman Mariun ...+1 more authors





Institutions: Universiti Teknologi MARA, Universiti Putra Malaysia, University of Malaya

Published on: 10 Jun 2015 - International Conference on Environment and Electrical Engineering

Topics: Voltage controller, Open-loop controller, Control theory, Voltage and Topology (electrical circuits)

Related papers:

- [Performance Measure of Shunt Active Power Filter Applied with Intelligent Control Technique](#)
- [A Modified Fuzzy Hysteresis Controller for Shunt Active Power Filter](#)
- [Adaptive Fuzzy Control for Shunt Active Power Filters](#)
- [Advanced PLL with multivariable filter and fuzzy logic controller based shunt active power filter](#)
- [Artificial Intelligent Controller based Three- Phase Shunt Active Filter for Harmonic Reduction and Reactive Power Compensation](#)

Share this paper:    

View more about this paper here: <https://typeset.io/papers/double-soft-computing-techniques-based-triple-42jzangdw>

Double soft-computing techniques based triple functionalities for shunt active power filter with voltage source inverter topology

ABSTRACT

Firstly, a unified adaptive linear neurons based fundamental component extraction algorithm for dual roles is developed; to generate and synchronize a reference current with respect to the phase and the frequency of supply voltage. A modified method of extracting the final amplitude of the reference current is introduced for improving the quality of the reference current. Second, a hybrid Fuzzy-Proportional (P) controller plus Crisp-Integral (I) controller is designed for a self-charging DC-link voltage control algorithm. The proposed controller is utilized in minimizing the error of DC-link voltage and, its control signal is employed in calculating a reference charging current. The Fuzzy-P controller exhibits simple structure for low computational burden and memory requirement. While, the Crisp-I controller is used to eliminate the steady-state error of DC-link voltage. Performances of the SAPF with the proposed techniques are validated by simulation and experimental works.

Keyword: Adaptive Linear Neuron (ADALINE); Fuzzy-proportional controller; Fuzzy-proportional-derivative controller and Crisp-integral controller; Hybrid controller; Shunt Active Power Filter (SAPF); Soft-computing technique